

Modify Section 03 00 01 per the following (deletions are shown struck through and additions are underlined). Remainder of section is unchanged.

03 00 01 Owner General Requirements and Design Intent

.01 General

- A. Air-entraining is to be specified for all concrete exposed to weather.
- B. The use of admixtures will be permitted only for air-entraining agent in specified type concrete. In this event, the concrete mix shall be adjusted to compensate for the admixture in a manner approved by the Professional.
- C. Antifreeze and other admixtures will not normally be permitted.
- D. On all exposed concrete floors, a hardener and dustproofing agent shall be used.
- E. All suspended concrete floors, including those in penthouse mechanical rooms, shall be watertight.
- F. All aggregate fill beneath any structural concrete component of the project, including slab-on-grade, must meet the "Structural Backfill and Compaction" specification in Division 31.

END of revision

Update Commentary:

Section was updated primarily for the following reasons:

- 1) Section was added to reference new "Structural Backfill and Compaction" Specification in Division 31.