

Modify 26 53 00 per the following instructions:

1. Changes are shown in **red**, using “Track Changes” function
2. Deletions are shown **struck through**
3. Additions are **underlined**
4. The remainder of section is unchanged.

Section affected:

26 53 00 EXIT SIGNS

.01 General

A. Exit lights shall be green LED and have stencil face with green letters. In small renovation projects, red LED may be used to match existing signs.

~~A-B.~~ Flush mount types are desirable because they are more vandal-proof. Consider vandal-resistant models for dormitory design.

~~B-C.~~ Self-contained exit signs powered by a radioactive source (tritium or similar) are not acceptable.

~~C-D.~~ Equipment shall be UL or CSA/US approved and labeled.

END of revision

Update Commentary:

Section was updated primarily for the following reasons:

- 1) Clarification that red LED exit signs are acceptable for small renovation projects to match existing.