

Modify subsection .01 in Section 22 11 00 per the following (deletions are shown struck through and additions are double underlined). Remainder of section is unchanged.

22 11 00 FACILITY WATER DISTRIBUTION

.01 Plumbing Piping

~~C.—Compressed Air Piping~~

- ~~1.—Compressed air piping above grade shall be Schedule 40, galvanized steel conforming to ASTM A 53. Fittings shall be malleable screwed end.~~

~~D.—Vacuum Piping~~

- ~~1.—Vacuum piping shall be Schedule 40 black steel with malleable screwed fittings, or Type L, hard drawn copper tubing with no lead solder joints.~~

~~E.—Natural Gas Piping~~

- ~~1.—Natural gas piping shall be Schedule 40 black steel with malleable screwed fittings.~~

~~F.—High Purity Water Piping~~

- ~~1.—High purity water piping, fittings, and valves shall be polypropylene with fused joints.~~

END of revision

Update Commentary:

Section was updated primarily for the following reasons:

- 1) *Information is incorrect in content and/or should not be in this section for regular plumbing water distribution. Will be corrected in other revisions to follow.*