

22 31 00 DOMESTIC WATER SOFTENERS

.01 Water Conditioners

- A. The need for water softening shall be determined on an individual project basis and approved by OPP Engineering Services.
- A.B. At University Park Campus, water softening by ion exchange technologies shall be prohibited. Water treatment for the removal of hardness shall be performed with other technologies, such as reverse osmosis.
- ~~B.~~ ~~Units shall be similar to Kiseo.~~